

GUJARAT FIRE PREVENTION AND LIFE SAFETY MEASURES RULES 2014

Extra No. 246 C) REGISTERED NO. L 2.FRNP/G/GNR-84 •oooh Cbe Gujarat Gubernment &2pette vol. LVI EXTRAORDINARY PUBLISHED BY •AUTHORITY TUESDAY, AUGUST 19, 2014/SRAVANA -28, 1936 Se arate a inois iven to this Part in order that it ma be filed as a Se arate Com ilation

PART IV-B t,,an (hose published in Part I, I-A and I-L) made Rules and Orders by the Government of Gujarat under the Gujarat Acts. URBAN AND URBAN HOUSING DEPARTMENT Notification Sachivalavn 19 August, 2014. PREVENTION AND LIFE SAFETY MEASURES ACT, 2013 No-GTI/V/156 of In exqrcise of the powers conferred by sub- section of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj. I ot-2013), (hereinaftei cefetfecci to as "the said Act") the Government of Gujarat hereby appoints, the date of publication ot-this notification, as the date on which the said Act, shall conie into Fc'ree, for the areas included within the;- jurisdiction limits of the urban development authority; frea development authority and the Nagarpalika as; spccified the schedule appended hereto- SCHEDULE 1- 2. 3. 4. 5. 6- 7. 8. 9- 11. 12. 13. 16- 17. Ahmedabad ;rban Development Authority Gandhinagar Urban Development Authority Rajkot Urban Development Authority Surat Urban Development Authority Vadodara Urban Development Authority Bharuch—Ankleswar Urban Development. Authority Surendranagar-Wadhavan IJrban Development Authority Morbi-Wankaner Urban Deveipment Authority Anand- Vidhyanagar-Karamsad Urban Development Authority Hirnmatnagar Urban Deveipment Authority Gift Urban Development Authority Junagadh Urban Development Authority Khambhaliya Urban Development Authority Jamnagar Area Development Authority Bhavnagar Area Development Authority Vadinar Area Development Authority Bhuj Area-Devetopment Authority 246-2 18. 19. 20. 21- 22

23. GUJARAT GOVERNMENT GAZETTE EX., Bhachau Area Development Authority Rapar Area Development Authority Anjar Area Development Authority Alang Area Development Authority Area Development Authority 19-08-2014 [PART-IV-B A] Nagarpalika declared under Gujarat Nagarpalika Act, 1963, except those included within the jurisdiction limit of the development authorities stated in sr. no. I to 22 above. By order and in the name of the Governor of Gujarat, NEELA MUNSHI, Officer on Special Duty and Ex-Offcio Deputy Secretary to Government. URBAN DEVELOPNIENT AND URBAN UOUSNG DEPARTMENT Notification Sachivalaya, Gandhinagar, 190 August, 2014- GUJARAT FmE PREVENTION AND 1 RFSAFETY MEASURES ACT, 2013 No.GHfV/1\$7 of 2014/PRCHw102013-382-L (Part-2):- Whereas, the draft rules, namely the Gujarat Fire Prevention and Life Safety Measures Rules, 2014 were published by the Government of Gujarat in the Urban DeVelopmerit & Urban Housing Departnrnent vide No.GH-V-l I of 2014-PRCH-1020 3-382-L(Part-2), dated.20.012014 in the Gujarat Government extra ordinary Gazette Part TV-B dated-20.01.2014, inviting o%jection and suggestions• Trom all persons likely to be affected thereby, before the expiiy•öf-thZ •ppriod of sixty days from the date on whiche copies of the Gazette containing the said notification. were made available to the public; AND WHEREAS, the copies ofth? said Gazette were made available to the dated-20.01.2014 AND WHEREAS, the objection and suggestions received within the said period from the public in respect of the said draft rules have been duly considered by the Government of Gujarat; • NOW THEREFORE, in exercise of the powers conferred by sectiog2 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj. 11 of 2013), the Government of Gujarat hereby makes the following rules, namely-- CHAPTER ShoH '171e, Extent and Commencement.- (1) These rules may be called the Gujarat Fire Prevention l. and Life Safety Measures Rules, 2014. (2) It extends to the whole of the State of Gujarat. (3) It shall come into force on the date of their publication in the Official Gazette

2. Definiüons.- (1) In these rules, unless the context otherwise requires:- (a) (b) (c) (d) (e) "Rot" means the Gujarat Fire Prevention and Life Safety Measures Act, 2013, (Guj. Act NO- 11 0f2013)•, "Fire Prevention Wing" means the Fire Prevention Wing created under rule 38; "Fire Safety Certificate" means the Fire Safety Cettificate issued under sub-rule (l) of rule 23; 'Form ' means 'Form' in appended to these rules; "Gujarat State Institute for Fire Safety Training" means Gujarat State Institute för Fire Safety Traininae. (GSIFST) established under sub-section (l) of section 17 of the Act; PART-IV-BI GUJARAT GOVERNMENT GAZETTE EX. 19-08-2014 246-3 (t) tSchedide' Incans a 'Schedule' appended to these rulo; (2) The words and expressions not defined in these rules but defined in the Act, or GOCR or National

Building Code of India or relevant Indian Standards or Specifications published by Bureau Of Indian Standards shall have the meanings as assigned to them in the Act or Building Bye-laws or National Building Code of India, 2005 or relevant Indian Standards or Specifications published by the Bureau of Indian Standards for construction and fire safety of buildings or premises and pandals- CHAPTER U ORGANISATION, ESTABLISHMENT AND ADMINISTRATION Qualifications of the Nominated Officer.— (1) For appointment of the nominated officer under clause (u) of sub-section (1) of section 2 of the Act, a person shall possess the qualifications as specified in First Schedule, Equipments and Appliances for Fire Service.- (1) The Director shall determine the requirement of equipments and appliances for rescue, fire fighting, personal protection in such numbers and with such specifications taking into consideration the apprehension of fire risk in the area for effective measures of safety and efficient response in times of emergency. (2) The Director, with the previous sanction of the Government, shall procure equipments and appliances determined under sub-rule (1) in such manner that each fire division is adequately equipped to meet with the requirement of fire fighting and fire safety measures and make all necessary arrangements for their upkeep and maintenance to ensure their availability to provide fire prevention and fire safety service as and when required. (3) The life of equipments and appliances shall be as per the recommendations of the Standing Fire Advisory Council of the Ministry of Home Affairs, Government of India or of any other authority as may be authorized by the Government for this purpose

5. Construction or hiring of places for, Fire Stations.- (1) The Director shall identify the area where the establishment of a fire station is tactically advantageous to provide fire prevention and life safety measure.- (2) The Director with the previous sanction of the State Government shall require the local authority to provide land on payment of such premium as may be fixed by the State Government. (3) The State Government may hire any building or premises on payment of such rent and on such terms and conditions as may be agreed to by both the parties where no land is made available by the local authority. The composition of the fire station along with the staff pattern and facilities to be provided by a fire station may be decided by the Director, depending upon the circumstances prevailing and apprehension of fire risk in the area. Qualifications for appointment of Fire Officer of different rank and other terms and conditions of service.- (1) The qualifications for appointment and other conditions of services of Fire Officer of different ranks shall be, specified by the State Government, by any general or special order in that behalf

7. Restrictions respecting right to association, etc—No member of the Fire Service shall participate in, or address, any meeting or take part in any demonstration organised by any person or persons for any political purposes or for such other purposes as may be prescribed

8. Badges of Ranks Fire Service.- Personnels serving at different ranks in any fire service shall have the badges of various as specified in the Second Schedule. CHAPTER m LICENSED AGENCY 9.

Eligibility for Licensed Agency. No person shall be eligible to apply for grant of licence to act as a Licensed Agency unless he,— 246-4 GUJARAT GOVERNMENT GAZETTE EX- 19-08-2014 IVART-IV-B (a) possesses at least any of the following qualifications, namely — a degree or Advanced Diploma or Diploma in Fire Engineering conferred or awarded by the National Fire Service College, Ministry of Home Affairs, Government of India; or (ii) Fellow of Fire Engineering of the Institution of Fire Engineering (I.K.) or M.I. Fire (U.K.). Or A.I.V.L.I.E. Fire India, Graduateship Examination of the Institution of Fire Engineering (U.K.) or the Institution of Fire Engineering (India); and (b) a degree or diploma in Mechanical or Electrical or Electronics or Chemical or Civil, Engineering obtained from a University established or incorporated by an Act of the Parliament or a State Act in India or an educational institution; or declared as deemed to be University under section 3 of the University Grants Commission Act, 1956 (3 of 1956); and (c) holds a solvency certificate for an amount as may be specified by the Director, with prior approval of the State Government; and (d) has the experience of 3 years immediately preceding the year of making the application, executed the work in field relating to fire prevention and fire- protection system or holds a certificate of fire protection specialist awarded by the Gujarat State Institute for Fire Safety Training, (GSFST) established by the Government; and has not been black-listed by any Government Department or authority established by a law of the (e) State Legislature; or any board or corporation or organisation owned controlled by the State Government or any other State Government.

10. Application for to act as Licensed Agency:— (1) Any person who intends to act as a Licensed Agency as specified under sub-section (2) of section 28 shall make an application in "Form A1 " for obtaining licence. Such application may be made in person or be sent by registered post acknowledgement or, through courier agency or online- (2) The application made under sub-rule (1) shall be accompanied by fees and fulfill other requirements as specified in the Table below:

Class of local authority	Minimum solvency prescribed limit for execution of the works as per estimated cost (Rs in lakhs)	Unlimited	1000	600	300
TABLE	Cost of annual works minimum executed in the last three years (Rs in lakhs)	Fire fighting	Detection of Passive installations such fire protection	(1) Municipal Corporation/ Special Investment Regions/ Industrial Estates	c For remaining Gram Panchayat areas -certificate for (Rs in lakhs)
(2)	25.0 15.0 10.0 5.0 2.5	as hydrants sprinklers pumping etc.	(4)	1500 500 300 200 -100	such as separation systems
(5)	600 200 100 50 25	(6)	600 200 100 50 25	Registration fees (Rs in lakhs)	(7) 25000 5000 2500

PART-IV-B1 GUJARAT GOVERNMENT GAZETTE EX- 19-08-2014 246-5 The Applicant shall furnish the following documents, namely:- (3) (i) (ii) (iii) (iv) (v) (vi) (vii) (viii) (ix) (x) (xi) solvency certificate for an appropriate amount as specified in column (2) of Table shown above; attested copy of partnership deed and of attorney or articles of association and memorandum of association or affidavit on stamp paper in case the individual is the sole proprietor of the firm; certificates satisfactory completion of works carried out in last three years-issued by the department; orders of works in hand in current year (upto the prescribed amount for that class); certificate from the Chartered Accountant or registered Income Tax Practitioner in the prescribed

form in of Private works; if the application for registration is made for the first time for a specific class, the applicant is required to have executed at least one work upto the maximum amount in the class, which falls by one below the specific class, applied for; certificate of appointment of at least one officer possessing any of the qualifications specified in clause (b) of sub-rule (1); attested passport photographs of partners or directors or individual proprietor and also of the officer or officers referred to in the application; affidavit on appropriate stamp paper, stating that his/ her firm is not black listed by any of the departments of the State Government, local authority or any board or corporation or organisation owned or controlled by the State Government or any other State Government; list of technical their qualifications; and such other and/or documents as may be required by the Director- 11. Licence to act as Licensed Agency.—The application made under rule 10 shall be scrutinised by the Director in accordance with the rules and on being satisfied that the applicant fulfills all the criteria for grant of licence to work as licensed agency, he shall grant the Licence in "Form-A1" to act as Licensed Agency subject to the following terms and conditions, namely (1) (2) (3) The licence shall be— (a) non-transferable, (b) valid from the date of issue, unless suspended or cancelled earlier, renewable for a term of two years, if so desired, before expiry of the licence. (c) Changes, if any in (a) partners, or members; (b) address of the office of the Licensed Agency. shall be forthwith reported to the Authority issuing the licence. The Licensed Agency shall always keep the work; executed, or being executed by it, open for inspection by the Director, Chief Fire Officer or any fire officer authorised by the Director or the Chief Fire Officer, 12, Renewal of Licence— An application for renewal of a licence granted under rule 11 shall be required to be made in "Form-A1" which shall be accompanied by a fee as specified under sub-rule (2) of rule 10 and also documents as mentioned in sub-rule (3) of rule 10. Notice to show cause as why licence be not suspended or cancelled. Where any person to whom the Licence has been granted contravenes any of the provisions of the Act or of the rules or fails to comply with the conditions of the licence or becomes unfit by reason of incompetency, misconduct or any other grave reasons, a notice in "Form-A3" shall be given to such person to show cause as to why the licence granted to him to act as Licensed Agency should not be Suspended or cancelled- 246-6 GUJARAT GOVERNMENT GAZETTE EXTRA, 19-08-2014 CHAPTER IV [PART-IV-B PROVISIONS RELATING TO FIRE PREVENTION AND SAFETY MEASURES 14. - Certificates to be issued by a licensed agency.- (1) A certificate regarding the compliance of the fire prevention and life safety measures in a building or a part thereof as required by or under the provisions of the Act, shall be issued by a Licensed Agency in "Form-B1" (2) The Licensed Agency shall issue a certificate in the months of January and July in each year regarding the maintenance of fire prevention and life safety measures in a building or premises being in good repair and efficient condition as specified in sub-section (2) of section 29 of the Act, in "Form-B2"- 15. Notice for the removal of objects or goods likely to cause the risk of fire- For the purpose of removal of objects or goods likely to cause the risk of fire, a notice in "Form-B3" shall be issued to the owner or occupier of building or premises, by the officer authorized in this behalf, directing him to remove, the objects or goods likely to cause the risk of fire, to a place of safety within a time as specified in the notice. (2) - On failure to comply with the directions given under sub-rule (1), a further notice in "Form B4" shall be given under sub-section (2) of section 22 to submit his reply as to why the objects or goods should not be seized, detained or removed- 16. Memorandum of seizure, etc and panchanama.—Where any objects or goods involving risk of fire are required to be seized, detained or removed under sub-section (2) of section 22, the memorandum of seizure, etc. shall be prepared in the "Form B5" and the panchanama shall be made in "Form B6" 17. Notice for entry and inspection. The notice to be given for entering and inspection required to be given under sub-section (1) of section 5.4 of the Act for ascertaining the adequacy or contravention of fire prevention and life safety measures in any place or building or part thereof, shall be in "Form B7". (2) The notice under sub-section (1) of section 5.4 of the Act to a woman, who according to the custom does not appear in public, shall be given in "Form B8" 18. Report. of Inspection.- The report of fire nominated officer relating to inspection carried out by him under sub-section (1) of section 24 of the Act shall be given in "Form B9" 19. Notice to the owner or occupier of a building or part thereof to undertake certain measures.—(1) On completion of the inspection of a place or building or a part thereof, if any deviation from, or contravention of, the requirements with regard to the fire prevention and life safety measures or any inadequacy or non-compliance of such measures provided or to be provided therein with reference to the height of the building or the nature of the activities carried on in such place or building or part thereof, are

noticed, the owner or occupier of such place or building or part thereof shall be given a notice in "Form-BIO", by the officer authorized in this behalf, under section 24 of the Act, directing him to undertake the requisite measures within seven days. (2) The time to be specified in the notice given to the owner or the occupier under sub-rule (1) shall be specified having regard to the nature of the measures to be taken but no such time shall exceed 120 days in any case



20. Procedure for sealing of a place or building or a part thereof-- The procedure to be followed by the Director or the Regional Fire Officer or the Chief Fire Officer in regard to sealing of any place or building or part thereof, as required sub-section (3) of section 26 of the Act shall be as follows, namely:- (a) (b) (d) he shall require the persons, in possession or occupation of the place or building or part thereof to be sealed, to remove themselves from there forthwith; in case of non-compliance of the said order, he shall direct any police officer having jurisdiction in the area to remove such persons from such place or building or part thereof; after the removal of persons in possession or in occupation from such place or building or part thereof, he shall cause such place or building or part thereof to be sealed by such police officer forthwith in the manner which he deems fit; the seal used to seal as aforesaid shall remain in the custody of the Director or, the Regional Fire Officer or the Chief Fire Officer, as the case may be; **PÄRT-IV-BI (ii) (iii) GUJARAT GOVERNMENT GAZETTE EX.19-08-2014 246-7** if the place or building or part thereof required to be sealed on receipt of the report of the nominated officer, is found to be locked or inaccessible, he may break open with the assistance of the Police officer and enter the premises and after taking all necessary steps required to be taken under the Act, or under these rules, relock and cause it to be sealed as aforesaid; where a place or building or a part thereof is sealed under sub- clause (i), an inventory of the material found in such place or building or part thereof shall be prepared in the presence of two independent witnesses and a copy thereof shall be delivered to the owner or occupiers if present at the site. The "



Form 135" for inventory and "Form B6" for panchanarna, respectively, shall be used for preparation of the reports; he shall make report in writing to the Police Inspector of the concerned Police Station if the seal so fixed on any place or building or part thereof is found to be broken or tampered 21. Appointment of Fire Safety Officer.- (1) For the purpose of effective fire prevention and life safety measures, every owner or occupier every factory shall appoint a fire safety officers within a period of six months from the commencement of the Act, having prescribed qualifications and thereafter shall send the compliance report to that effect in Form B1 I to the Regional Fire Officer or the Chief Fire Officer. (2) On the receipt of the compliance report made under sub-rule(1), the Regional Fire Officer or the Chief Fire Officer, shall after due verifications, issue a certificate of enrolment of appointment of the fire safety officer, under the seal and signature of the Regional Fire Officer or the Chief Fire Officer or any other authority in "Form B1T. (3) In case of failure to appoint a fire safety officer as specified in sub-rule the Regional Fire Officer or the Chief Fire Officer shall, after giving an opportunity of being heard, if it is considered to do so, communicate to the relevant authority or to the labour commissioner to take appropriate action for the discontinuance of the use or closure of the building or premises or the factory, as case may be, (4) The classification of buildings or premises and the of the Fire Safety Officer shall be as specified in the Third Schedule; 22. Minimum standards for fire prevention and fire safety for buildings or premises-- (1) The minimum standards for fire prevention and fire safety for buildings or premises required under sub-section (2) of section 18 of the Act, with respect to the height of the buildings and class of occupancy as provided in the building bye-laws or National Building Code of India, shall mutatis mutandis apply in the following matters, namely:- (a) (b) (d) (e) (f) (h) (i) (j) (k) (m) (n) (o) (p) (q) (r) (s) access to building number, width type and arrangement of exits, protection of exits by means of fire check door (s) and or pressurization, compartmentation, smoke management system, fire extinguishers, first-aid hose reels, automatic fire detection and alarming system, public address system, automatic sprinkler system, internal hydrants and yard hydrants, pumping arrangements, captive water storage for fire fighting, exit signage, provision of Lifts, standby power supply, refuge area, fire control room, special fire protection systems for protection of special risks: 246-8 GUJARAT GOVERNMENT GAZETTE EX-, 19-08-2014 [PART-IV-B Provided classes of occupancies or buildings or premises for which fire prevention and fire-safety measures are not provided in the building bye-laws or National Building Code of India, the Director may the owner or occupier of such or buildings or premises to provide fire prevention and fire safety measures in accordance with the international standards as may be provided by the Fire Prevention Wing: Provided further that where the Government is of the opinion that it is necessary or expedient to do it may, by order, for, reasons to be recorded or modify or annul any requirement concerning fire prevention and fire safety measures these rules with respect to any class of occupancy in any building or premises in special areas or in respect of any building or premises in any area that was constructed or which was under construction prior to the date of commencement rules. (2) Where the Regional Fire Officer or the Chief Fire Officer is of opinion that it is necessary or expedient to do so, it may, reasons to be recorded in writing, require the owner or occupier of the buildings or premises to provide additional fire prevention and fire safety measures. Issuance of Fire WU Certificate. - (1) The Regional Fire Officer or the Chief Fire Officer or any 23. other officer (s) authorised him in this behalf by a general or special order shall issue a Fire Safety Certificate in "Form B13" owner or occupier of the building or premises with such conditions may be specified in the Fire Safety Certificate for compliance of fire prevention and fire safety measures as specified under these rules. (2) The application for grant of Fire Safety Certificate shall be made to the Regional Fire Officer or the Chief Fire Officer in "Form B14" and shall be accompanied with a certificate from the architect and owner or occupier to the effect all the fire prevention and fire safety measures as required under rule 22 have been incorporated in the building or premises. (3) On receipt of the application made under sub-rule (2), the building or premises shall be inspected by the Fire Officers to ascertain the availability and operability of the fire prevention and fire safety measures who shall send his report with recommendation to the Regional Fire Officer or the Chief Fire Officer for grant or refusal of fire safety certificate. (4) On receipt of the recommendations under sub-rule (3), the Regional Fire Officer or the Chief Fire Officer shall grant the fire safety certificate in the relevant prescribed form or reject the same for reasons to be recorded in writing and communicate to the owner or occupier, as the case may be. (5) In case of rejection of application for grant of fire safety certificate under sub-rule (4), a fresh application shall be made by the owner or occupier under sub-rule (2) duly complying with the requirements as

communicated under sub-rule (4) (6) The buildings or premises that have already been issued 'No Objection Certificate' for the occupancy of the building or premises shall be deemed to have been issued 'Fire Safety Certificate' under rule 23 subject to verification of compliance of fire prevention and fire safety measures on which the 'No Objection Certificate' was issued on the last occasion, 24. Duration of Fire Safety Certificate.- The fire certificate issued under rule 23 unless sooner cancelled shall be valid for a period of 5 years for residential buildings (other than hotels) and 3 years for non-residential buildings including hotels from the date of issue: Provided that the Regional Fire Officer or the Chief Fire Officer may reduce the period after recording the reasons therefor.



25. Renewal of Fire Sddy Certificate-- (1) Application for renewal of fire Safety Certificate granted under rule 23 shall be made b the Regional Fire Officer or the Chief Fire-Offcer, in Form 'BU' along with • a copy of the Fire Safety Certificate prior to one month before of the expilY date of the Fire Safety Certificate.(2) On receipt of an application made under sub-rule (1), the Regional fire Officer or the

Chief Fire Officer or any other officer authorised by him shall inspect the building or premises to verify the compliance of rules and forward the rep«t of the compliance or otherwise; to the (3) On receipt of report under sub-rule (2), the Regional Fire Officer the Chief Fire Officer or any Other officer- authorised by him in this behalf by a special or general order, the Fire Safety Certificate for a period specified under rule 24 or reject the application duly recording the reasons therefore. PÄRT-IV:BJ GUJARAT

GOVERNMENT GAZETTE EX. 19-08-2014 246-9 Liability to maintain fire safety measures- (1) The occupier Of the building or premises, as the case 26. may be, shall maintain the fire prevention and fire safety measures provided in the building or premises at all times in best repairs for use by the occupants or members of Fire Service or both in the event of an out break offire- (2) The occupier of the building or premises or the Fire Safety Officer appointed under section i 2 of the Act, as the case may be, shall declare

every year in Form 'B 15' that fire prevention and fire safety measures provided in the building or premises- (3) It shall be lawful for the the Regional Fire Officer orthe Chief Fire Officer, to enter and inspect the building or premises, as the case may be, with a view to verifying the correctness of the declaration made under sub-rule (2) and to point out the shortcomings, if any, with directions to remove them within a specified time. If the directions of the inspEcting officer are not complied within the time limit so given, the Inspecting officer with lbe previous approval of the the Regional Fire Officer or the Chief Fire Officer shall declare the building or premises unfit from fire safety point of view and direct the local body/ authority or any other authority eoncraed to disconnect the electricity and water supply to the building or the premises, as the case may be, and the local body/ authority or the other authority shall comply with the directions of the inspecting officer. (4) ne owner or the occupier.ofthe building or premises or the Fire Safety Offcer, who falsely makes declaration, in contravention of the provision made

under sub-rule (2), shall be deemed to be in default and shall be liable to penalty. CHAP'rER V PROVISIONS FOR TENTORARY STRUCTURES 27. Minimum siandqrdsforfire prevention *emporary structure, etc.- (1) The minimum Standards for fire prevention and fire safety for temporary structure 'uch

as mandap, shamiyana or tents or pandal for the purposes of subsection (2) of sectioni 27 shall be-required in accordance with published by Bureau of Indian Standards, New Delhi and National Buinding Code of India. relating to the following matters. lātne.ly:- .(a) (c) (d) (e) (0 (g) (h) (i) access temporary structures etc; open space around the temporary structures etc; distan•ce from mdium and high voltage electrical

wires and hazardous installations, means of exits, material of construction, first-aid fire fighting arrangements, water storage for fire fighting, electrical wiring, availability of trained fire staff. (2) ne promotér, organizer or the• or occupier shall require provide and maintain the measures specified in sub-rule 28. Form.of declaration.- The erector of temporary structures such as mandap, shamiyana or tents or

pandal shall, for the purposes of. due compliance of sub-section (2) of section 27 of the Act, make a declaration in Form 'Cl ', to the effect that adequate fire safety measures have been taken as provided in rule 29. Removal of encroach ...e z tEgoods likely to cause a risk of fire or any obstruction Io fire

fighting.- (1) The Sub-Divisional Magistrate having jurisdiction may, aner giving a reasonable opportunity of being heard as provided by sub-section (7) of section 27 of the Act may order to seize, detain or remove encroachments or objects or. goods likely to cause a risk of fire or obstruction to fire fighting. (2) Iheorder

under sub-rule (1) shall bennde in

Form cc2' and the panchnamashall be made in Form cc3'. (3) The notice to the person in possession of the inventory of the objects or goods as required under sub- •section (8) of section 27 of the Act shall be given irrFörm 'C4'. 246-10 GOVERNMENT GAZETTE 19-08-2014 (PART4V-B 30. Notice to pay the charges for the services rendered by the Srote Fire Services.- (I) Where thc State Government has provided the servics for Fire-prevention anWLife Safety Measures, the Director may iSS11C notice in Form C5 requiring the owner or the occupier of thebuilding or premises» to paythe amount for the expenses incurred for rendering the aforesaid services- 31. io he taken for fire prevention and life sgrety in temperory structures— The measures required to be taken by the promoter, the organizer or the owner or the occupier declared unßer sub-section (1) of section 27 of the Act* shall be such as specified in sub-rule(1) ofu-u!e 27. (2) • The show cause notice to be issued by the Sub-Divisional Magistrate under sub-section (6) of section 27 of the Act sha}l be as specified in Form C6- (3) The Regional Fire Officer orthe Chief Fire offcer may grant permission, in ffrm C8, subject to such conditions, as specified therin, for the use of temporary structures a 'hamiY01ä tent* or mandap, on receiving the declaration by the promoter or the organizer or the owner or the occupier of permises in form C7, the measures taken by him as Specified in sub-rule(1) of rule 27 s. (4) The Director or the Regional Fire Officer or the Chi?f Fire Qffcer or the Nominated omcer may, under sub-section (4) of section 27 of the Act, inspect the premises ensuring the correctness of the declaration made in form C7 or and in case of inadequacy, give necessary directions to comply, within the specified time, toothe prömotek or thé.okgahizer of the owner or the océupier. (5) In case of failure to comply any directions given under sub-rule (4) by the Mid officer may seal or dismantle the temporary structures a or tent or mandapand recover the incurred thereof from the promoter or the organ izer or the owuwr or the occupier. (6) The Regional Fire Officer or dE Chief Fire officer or any authorized officer, in this behalf, if finds that there exists any encroachment or obÄ or goods, which may cause or likely to cause a risk pf fire or any obstruction to firefighting, he may direct to remove, within specified time, such encroachments or objects or goods. (7) On failure to comply with the directions givéh under sub-rule (6), by the thf promoter or the organizer or the owner or the occupier, the said officer shall take necessary action as per sub-section (6) of section 27 of the Act. (8) On receipt of the report given by the Regional Fire Officer or the Chief Fire officer or any authorized officer, of tye encroachment or objaets or goods—which may cause or likely to cause a risk of fire or any obstruction to firefighting, may make an order in form C2 to seize, detain or remove it (9) The person authorized under sub-rule (8), shall give a notice in form C4, to prson in possession, that the goods and objects Seized, detained or removed shall be sold if they are not claimed within the time specified in the notice. (IO) Any person aggrieved by an order tmder sub-rule (7) or a notice issued sub-rule (8) may prefer an in form C9 which shall be accompanied by a copy of order or notice appeaH against and by a fee of Rs. 5,000/- (Rupees five thousand only) through a bank draft drawn in favour of dE Director, Gujarat • •State Fire Service payable at Gandhinagr. Cl I) The appellate authority shall all the circumstances of the case and aner making necessary inquiry as it deem fit pass such ordexs as it may deem just and proper and his order Shal) final (12) The authority which made the or issued the notice on which the appeal was preferred shall give effect to the order passed by the appellate authority. CHAPTER TRAE-UNG TO FIRE PERSONNEL 32. Training Charges.- The trainee shall pay •at the time of admission training charges as specified in the Forth Schedule by demand draft payable to the Principal, Gujarat State Institute for Safety Training, (GSIFST): Provided that, the trainees on the roll of State Fire Service shall not be liable to py training charges

33. Mamgrfor remittance offraiüg•charges-- (I) The Principal, GSFST shall Emit or cause to remit to äe Director, State-Eiæ Service at the end of each course the total sum of the ü•aüg charges received under the heads of tuition fee? charges, fire ground operation charges; accomhodAtion charges.PART-TV-BI GUJARAT GOVERNMENT GAZEITE EX. 19-080014 246-11 (2) The Director, shall maintain a separate head for remitting the training charges received and shall utilize the same for providing amenities like sports facilities (indoor and outdoor), and indoor recreation facilities to the trainees. 34- Training charges•to be non-refundable.- If any trainee decides to withdraw from the course before the date of closing of training schedule for whatever reasons or expelled from the course by the Principal, GSIFST he shall not be entitled to refund of training charges remitted by him under rule 32 in full o/ part thereof

35. Security Deposit.- (I) On admission of an trainee to a course, if he is allotted accommodation, he shall be required to deposit a sum of rupees one thousand only as security deposit by a bank draft, to the

Principal, GSIFST: Provided that, the trainees on the roll of State Fire Service shall not be liable for payment of Security Deposit. (2) The security deposit shall be refunded -at the end of course after verifying that all articles made available to him are in good condition and no losses has caused to the exchequer during the training by his conduct. CHAPTER v-m APPEAL 36. Appeal.- (1) An appeal to the Appellate Authority under section 33 of the Act shall be preferred in Form C9 and shall be accompanied by a copy of order or notice appealed against and by a fee of Rs- 5,000/- (Rupees five thousand only) through a bank draft drawn in favour of the Appellate Authority. (2) The appellate authority shall consider all the circumstances of the case and after making necessary inquiry as it deem fit pass such orders as it may deem just and proper and his order shall be final- (3) The authority which made the order or issued the notice on which the appeal was preferred shall give effect to the order passed by the appellate authority. •

37. Compounding of offences.- The offences punishable under the Act, specified in column (2) may be compounded either before or after the institution of prosecution by the officer specified in column (2), for the amount specified in column (3) of the Table below;- Table Offences and Penalties under the Act
Officer Regional Fire Officer Or the Chief Fire Officer Sub-section Sub-section Sub-section Sub-section Sub-section Sub-section Sub-section Sub-section I I 4 2 3 4 I 3 or Section 18 of Section 19 of Section 21 of Section 22 Of Section 24 of Section 27 of Section 29 Of Section 29 Fine Rupees 10000 10000 10000 10000 10000 10000 10000 10000 CHAPTER GENERAL MEASURES FOR FIRE PREVENTION 38.

Fire Prevention Wing.- There shall be constituted a Fire Prevention Wing' for the State Fire Service, or for local authority under the Director or the Chief Fire Officer consisting of such other fire officers and other personnels as the State Government may by notification in the Official Gazette declare or the local authority may declare by an order, as the case may be- 39. Powers and Functions of Fire Prevention Wing:

(1) The Fire Prevention Wing or officer authorized by it, shall examine the building plans referred to Fire Service by local authority or any other statutory authority for compliance by the owner or occupier under the regulations made under sub-section(2) of-section 18 of the Act- 246—12 GUJARAT GOVERNMENT GAZETTE no. 1508-2014 [PART-IV-B (2) The Fire Prevention Wing shall have the following powers and functions-in addition to sub-rule(1), namely: (a) (b) (c) (d) study the trends in fire accidents in the region and assist in framing the policies in the matters connected therewith for the fire prevention and fire safety and similar other matters incidental thereto, requirement and deployment of fire fighting equipment and appliances, planning for new fire stations and prepare training for Fire Service; study the provisions relating to fire prevention and fire safety as contained in other Acts, Statutes, and Regulations for the time being in force; in consultation with the Government counsel, defend the cases in various courts of law; organize mass- awareness programs on fire and fire safety and prepare leaflets and other advertisement material in electronic form for distribution to the public free of any charges

40. Fire Service response to an Emergency.- The Fire Service response to an emergency arising due to an outbreak of fire or any other emergency requiring Fire Service-intervention shall be carried out in accordance with the directions given by the Regional Fire Officer

41. Issuing of Fire Report- (h) A fire report shall be made available on line or otherwise within 72 hours of the date of occurrence Of fire to the Director for every fire accident and special service call responded to by the any Fire Service. The owner or occupier whose property was by fire or otherwise by whatever way may obtain the copy of report from the Director- (2) In case owner or occupier requires any change in facts reported in the fire report he or she shall make an application in



Form DI to the Director who may after satisfying himself allow the change requested for and record the same on the fire report 42. Adequate supply of water for firefighting-- (1) Notwithstanding anything contrary to the provisions in any other Act or rules for time being in force, the Regional Fire Officer or the Chief Fire Officer, as the case may be, may require the authority having jurisdiction to provide hydrants at strategic locations on the public mains or—private mains of not less than 150 mm diameter on payment of charges as demanded by such authority. (2) The residual pressure at the hydrant shall not be less than 1.5 bar (20 lbs. per square inch)- There shall be provided near each hydrant provided under Sub-rule (1) an identification plate (3) showing hydrant number and size of mains and each such hydrant shall be maintained by the authority which provided the hydrant- 43. Directions of Fire Officer relating to supply of electricity or water or removal of persons from, a place or building or, part thereof which is in imminent danger:— (1) The Director or the Regional Fire Officer or the Chief Fire Officer, may make an order under section 26 of the Act, directing the responsible authority, (a) in Form D2 to supply or disconnect electricity or water, as the case may be, to a place or building or a part thereof, which is dangerous to any person or property and (b) in Form D3 to any Police Officer having jurisdiction in the area, to remove persons from any place or building or part thereof which is dangerous to any person or property, and the said authority or the police officer, as the case may be, shall abide by such directions and he shall be responsible for the compliance of the orders passed 44. Duties and responsibilities of fire officers and staff.- Subject to the provisions of this Act and the rules made there under, the Director with the approval of the State Government shall, by general or special order, prescribe the duties to be performed and responsibilities of the personnel of Fire Services. 45- Requisition of firefighting equipment —For the purpose of sub-section (1) of section 13 of the Act, the Director or any Fire Officer may, by order in Form D4 direct to requisition any fire fighting equipment or property of any authority or any institution or individual in the event of fire

46. Report of damage caused to premises during firefighting operations and assessment and payment of compensation.- (I) The Director or the Regional Fire Officer or the Chief Fire Officer or any other fire officer who is in-charge of fire fighting- operations on the spot, shall make a--report in



Form D5 to the respective local authority as to the damage caused, if any, to the premises by fire officers or fire during fire fighting and rescue operations referred in Part IV-BI GUJARAT GOVERNMENT GAZETTE EX. 19-08-2014 246-13 (2) On receipt of report made under sub-rule the same shall be assessed by an officer of the respective Local Authority as may be notified in that behalf and such nominated officer shall, after giving an opportunity of being heard to the owner or occupier concerned, assess the damage and submit his recommendations in that behalf to the authority for its consideration. (3) Having regard to the recommendation made by nominated officer under sub-rule (2), and where the building or property to which such damage is caused is insured* the Insurance Company shall while, determining and granting compensation to be paid to the owner or occupier take into account the damage caused to the premises or any other property by the fire officers or fire personnel during the conduct of and rescue operations- 47. Report of accident to fire officer or fire personnel during fire and payment of compensation., The fire officer in-charge of fire, shall submit a report of any accident occurred during such fire fighting or rescue operations, in case of natural calamity or to the Director, the Regional Fire Officer or the Chief Fire Officer and the compensation payable to any fire officer, or fire personnel in the case of such accident, to their dependents in the case of death permanent disability, shall be such as may be determined by the Director may with the approval of the State Government or the local authority, as the case may be- 48. Employment of fire officer or fire personnel for purposes other than firefighting within or outside the sphere of their duties.- The fire officers or fire personnel may be engaged for the purposes other than fire fighting at the discretion of the Director or the Chief Fire Officer or any subordinate officer authorized by the Director or the Chief Fire Officer, in the case of all calls relating to natural calamities and rescue of life

49. Rates for supply of water required on the occasion of firefighting operations.- Where the officer in charge of the fire fighting operations draws water, from any source in the area, which he considers necessary for such operations, the authority or owner or occupier having control over such water source shall be paid for the water so utilised,— (a) if water is drawn from an authority, then at the lowest rate of supply of water which is usually charged from the users of water in that area by such authority; (b) if water is drawn from any owner or occupier, then at the rate which shall not exceed the 50. lowest rate referred to in clause (a), and where such rate is not available, then at such rate as may be determined by negotiation, subject, however, to the condition that where any dispute arises as to such rate, in the case of an authority, the decision of the authority -competent, and in the case of an owner or occupier, the decision of the Director, shall be final. Terms for securing personnel or equipment Or both for fire fighting purposes.- The terms on which the Director or the Chief Fire Officer or any other fire officer authorized by any authority may secure, by agreement, fire fighting equipment or personnel from any person who employs and maintains personnel and equipment both, for fire fighting purposes, shall be as follows, namely;— (2) As soon as may be, after the fire fighting operation is over the Director or the Regional Fire Officer or the Chief Fire Officer or any other Fire Officer in charge of the fire fighting operation; as the case may be, shall relieve the personnel or equipment so secured and restore the same to the person, including the local authority, firm and institution or individual, from whom the services of personnel and possession such equipment were secured. There shall be paid to the employer of such personnel or owner of such equipment, compensation, the amount which is in accordance with the principles hereinafter set out, namely:— (a) (b) (c) where the amount of compensation is determined under the agreement, it shall be paid in accordance with such agreement; where such compensation is not settled in the agreement or where no such agreement with regard to compensation can be reached, the matter shall be referred to the State Government or the local authority, as the case may be and the decision of the State Government or the local authority, as the case may be, shall be final; if any injury is caused to any personnel or any damage is caused to any equipment and the employee or the owner of the equipment, as the case may be, demand any compensation separately in respect thereof, and no agreement can be reached, the GUJARAT GOVERNMENT GAZETTE , 19-08-2014 [PART-IV-B matter shall likewise be referred to the State Government or the local authority, as the case may be, for determination and the decision of the State Government or the local authority, as the case may be, be final

51. Rewards.- (I) The Director or the local authority, as the case may be, may sanction rewards by way of certificate or cash rewards or with bonus to the personnel of any Fire Service for meritorious performance of duties, to the extent as specified in the Table below:-

Sectioning Authority	(1)	(2)	(3)
Director	me		

Regional Office or the Fire Officer The Deputy Fire Officer Provided that the Fire Chief Chief TABLE
 Type of commendation 3) Commendation Roll Commendation Certificate Class I Commendation
 Certificate Class II Cash Rewards 4 Up to Rs, 5,000/- in each case for actions of outstanding merit. Up to
 Rs. 3,000/- in each case for actions of Fair merit Up to Rs. 1,000/- in each case in recognition of
 exemplary performance or to Fire Service on the occasion of fire and/ or rescue: State -Government or the
 local authority may on the recommendation of the sanctioning authority, each case, grant rewards up to Rs.
 10,000/- (Rupees ten thousand only) in recognition of specific instances of exemplary performance or
 assistance by the members of any Fire Service on the occasion of fire and or rescue .. (2) The rewards to
 the members of Fire Service under sub-rule (1) shall be recorded in the Service Book in ink by the
 authority granting such reward. Power of Director to give directions.-(i) The Director with the previous
 approval of the Government, may issue such directions as are necessary for the efficient administration
 of the fire service which may among others, include the followings, namely:- (i) (ii) (iii) (iv) (v) (vi) (vii)
 (viii) training to members of fire service; discipline and good conduct of members of fire service; speedy
 attendance of members of fire service with necessary appliances and equipment on the occasion of any
 alarm of fire; conditions of service of the members of Fire assigning duties to fire officers of all ranks
 grades, and prescribing the manner in which and the conditions subject to which they shall exercise and
 perform their respective powers and duties; institution, management and regulation of any Fire Service
 fund for any purpose connected with policy administration; maintenance of Fire Service equipment and
 appliances to keep them in due state of efficiency; and generally for the purposes of rendering the Fire
 Service efficient and preventing abuse or neglect of their duties



53. Power of Director to have assistance of police officers.- The Director or the Regional Fire Officer or the Chief Fire Officer or any other fire officer while performing his duties in Fire Fighting operations or any other duties of seizure, detention or removal of any goods involving risk of fire may require the assistance of a police officer or members of the police force as an aid in performance of such duties and it will be the duty of police officer of all the ranks or such gentlemen to aid the Director or such fire officer in the performance of their duties under this Act. PART-IV-B] Serial Number (1) (1) (2) (3) GUJARAT GOVERNMENT GAZETTE EX. FIRST SCHEDULE (See rule 3) Qualifications for the appointment of Nominated Officer

246-15 Municipality (2) Municipal Corporation Municipalities, or Notified Area or Industrial Townships. Special investment Region and Special Economic Zones (SEZs), Private Townships

Qualifications (3) The State Government shall time to time, by an order prescribe the qualifications. The State Government shall time to time, by an order prescribe the qualifications. 246-16 GUJARAT GOVERNMENT GAZETTE EX., 19-08-2014 SECOND SCHEDULE Badges of Ranks in Fire Service (See rule 3) [PART-IV-B Badges of Ranks, Peak Cap, Collar Patches and Helmet Markings.- The Badges of Ranks, Peak Cap, Collar Patches and Helmet Markings for various posts in Fire Service shall be as per the table Sr- No. 3 4 5 6 7 8. below:-

Sr- No.	Name of the post	Director	Chief Fire Officer	Divisional Officer (Fire)	Assistant Divisional Officer	Sab-Officer	Leading Fireman	Badges of rank
3	Director							Cross sword and baton with one small impeller 3/4" diameter + Shoulder "GSFS"- Ashok emblem with three small impellers 3/4" diameter + Shoulder titles "GSFS"- Ashok emblem with one small impeller 3/4" diameter + Shoulder titles "GSFS"- Ashok emblem with three small impellers 3/4" diameter + Shoulder titles "GSFS". Two small impellers 3/4" diameter + Shoulder titles "GSFS"- Two small impellers 3/4" diameter with blue strip + Shoulder titles "GSFS"- One bar 1/2" wide and 1 1/2" long with semi-circular cross section with flat bottom surface and round surface on top made out of white metal + Shoulder titles "GSFS"- Collar Patches Blue black collar patches with two rows of oak leaves as per drawing- One silver line 7 cm long line on blue blazer cloth- One silver line 4 cm long line on blue blazer cloth- Not applicable- Not applicable Not applicable Not applicable Peak Cap Two rows Of silver oak leaves on peak embroidered badge and black band placed around the head level. One row of silver oak leaves on peak, embroidered badge and black band placed around the head level. One row of silver oak leaves on peak, embroidered badge and black band placed around the head level- Plain peak with- embroidered badge- Plain peak with embroidered badge. Plain peak with metal badge. Plain peak with metal badge. Khaki Beret with metal badge- Helmet White with one 38 mm black band. with two 19 mm black bands with 12.5 mm separation. White with three 12.5 mm black bands with 12.5 mm separation. White with two 12.5 mm black bands with 12.5 mm separation. White with one 12.5 mm black band. Yellow with one 12.5 mm black band- Yellow.
4	Chief Fire Officer							2" diameter, 3 spokes steering wheel embroidered in white on blue black ground + Shoulder titles "DFS".- Shoulder titles "GSFS" Collar Patches Not applicable Not applicable Peak cap Khaki Beret with metal badge. Khaki Beret with metal badge- Helmet Black Black Car Flag and Star Plate.- (1) The staff car used by the Director shall have displayed on the bonnet a flag made out of blue black blazer cloth and star plate on front and rear side bumper of the staff car as per drawing. (2) The staff car used by the Chief Fire Officer shall have displayed on the bonnet a flag made out of blue black blazer cloth and star plate on front and rear side bumper of the staff car as per drawing_
5	Divisional Officer (Fire)							246-18 GUJARAT GOVERNMENT GAZETTE EX., 19-08-2014 FIRST SCHEDULE (See sub-rule (4) of rule 21) Classification of Buildings for Appointment of Fire Safety Officer [PART-IV-B The Fire Safety Officers of different Ranks shall be appointed for different class of buildings namely: Class of building 1 2 3 4 5 1 2 -3 Buildings cinema houses with seating capacity of more than. 1000 persons and having commercial complex with built-up area more than 10000 sq. and building having multiple cinema with seating capacity, taken together, of 1000 persons, or more, whether, having commercial complexes or not; underground shopping complexes, district centers, sub-central business districts, including the basement with built up area of more than- 25000 sq. mm; large oil and natural gas installations such as refineries, LPG bottling plants and similar other facilities; open stadia with seating capacity more than 50,000 persons and indoor stadia with seating capacity more than 25,000 persons; public and semi-public buildings like large surface* and sub-surface railway stations, interstate bus terminuses, airports amusement parks and other similar buildings: hotels

with 100 rooms and above; multistoreyed non-residential buildings above 50 meters in height; hostels and nursing homes with more than 500 beds; Rank of Fire Safety Officer Deputy Chief Fire Officer Divisional Officer (Fire) 8- Class of occupancies likely to cause risk of fire.- the following classes of occupancies for the purposes of sub-section (I) of section 25 of the act shall be construed to likely cause risk of fire, namely:- (a) (b) (d) (f) (g) (h) (i) pandal having seating capacity more than 50 persons or covered-area more than 50 square meters- residential buildings (other than hotels and guest houses) having height more than 15 meters or having ground plus four upper stories including mezzanine floor. hotels and guest houses having height more than 12 meters having ground plus three upper stories including floor. educational buildings having height more than 9 meters or having ground plus two upper stories including mezzanine floor. institutional buildings having height more than 9 meters or having ground plus two upper stories including mezzanine floor. all assembly buildings- business buildings having height more than 15 meters or having ground plus four upper stories including mezzanine floor- mercantile buildings having height more than 9 meters for having ground plus two upper stories including mezzanine floor: industrial buildings having covered area on all floors more than 250 square meters. storage buildings having covered area on all floors more than 250 square meters. all hazardous buildings having covered area on all floors more than 100 square meters. underground buildings.- the minimum height of the buildings for the purposes of sub-section (f) of section 33 and Sub-section (I) of section 35 of the act shall be as specified in rule 27- PART-IV-B] 1. GUJARAT GOVERNMENT GAZETTE EX. 19-08-2014 FOURTH SUPPLEMENT Training Charges at Admission to Course (See rule 32) 246-19 Training Charges.- The training charges to be paid by each external trainee at the time of admission to any course of study conducted at GSIFST or at any other place as may be determined by the Director shall be determined based on the duration of the course in accordance with the table below:

Trainee's Course Duration (Weeks)	1	2	3	4	6	12	24
Accommodation Charges	500	1000	2000	4000	8000	16000	32000
Tuition Fee	500	1000	2000	4000	8000	16000	32000
Fire Ground operation charges	1000	1000	1500	3000	4000	5000	6000
amenities [Excluding week Barrack]	250	250	250	250	250	250	250
Single	1000	1000	1000	1000	1000	1000	1000
Double	500	500	500	500	500	500	500
fund accommodation charges	100	200	300	400	600	1200	2400
2, Trainees' Amenities Fund	2200	2800	3900	6600	11200	17400	24600

2, Trainees' Amenities Fund to be paid by members of Fire Service.- All the members of Fire Service undertaking a course of study at GSIFST shall pay the trainees' amenities fund determined under clause (I) at the time of admission, Revision of Training Charges.- The training charges-Shall be revised every three years at the rate as may be determined by the Government. 24600 To, GUJARAT GOVERNMENT GAZETTE EX-, 19-08-2014 FORM A1 (See sub-rule I and rule IO)

Application for Licence to act as Licesance. Agency [PART-IV-B The Director Sub: - Application for Licence to act as Agency The undersigned hereby applies for want of or renewal of License to act as a Licensed Agency for undertaking and executing the work of providing installation of equipments and maintenance of fire prevention and life safety measures in any building or part thereof. The particulars regarding the Agency are given below:-

2. 3- 4 5. 6. 7- 8. 9 Full Name of the Applicant (In Whether Licensed Agency will be a Proprietary Concern or an Association of persons such as a Firm or Company etc- Registration of Firm or Company (Copies of Registration Certificate, article of Association or other relevant document attached, Address If the Licensed agency will be: a. proprietary concern, the name, qualifications and address of the person operating the same- b. a firm or company, names, qualifications and addresses of each of the partners, or as the case may be Directors- Office address where the Agency will act as a Licensed Agency— Class for which Licence is applied for - Personnel with the Agency - a. star, name, qualifications and addresses of each. b. Other employees names qualifications and addresses of each. Details of work with regard to fire Prevention and life safety measures, if any; undertaken and executed previously. a. Name or nature of work Approximate cost of work c. Whether the work executed or still in progress and remains to be executed, (Note—Original or attested copies Of Certificate verification of above details by the officers under whom works are carried-out are attached . IO Technical qualifications and experience of the promoter or partners of directors and dealing 11 12 13 14 15 16 17 technical officers or employees with the applicant. Workshop machinery, tools and plant owned by the applicant, (location and site Of workshop and full details to be given). Whether enlisted with any other department or Organization in any other State. If so, in which category, Has the applicant ' or- his partners or Directors been blacklisted in the past by any Government Department/ organization/other State? b- Has the applicant applied for registration elsewhere In his name or in the name of partner. Director or firm or

com ? If so, whether the location is affected? Give particulars. Whether the applicant has produced up to date Income tax certificate. Amount of solvency certificate which the applicant has held or produced. A fee of Rs. remitted herewith by Demand Draft No. Dated. Drawn on Bank. If the application is for renewal of the existing licence, the details in respect of the licence and the conditions of the licence and whether, the licence to act as Licensed Agency granted anytime previously has been suspended or cancelled- and if so reasons therefor- I/We certify that J/We have not been and will not let myself or ourselves registered as contractor -in the department under more than one name. Thanking you, Yours faithfully PART-IV-BI GUJARAT GOVERNMENT GAZETTE 19-08-2014 FORM A2 246-21 License to act as a Licensed Agency for fire Prevention and life Safety Measures Licence No. (See rule 11) Date:- Licence is hereby wanted or renewed under the provisions of sub-section (1) of section 28 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Gujarat Act 11 of 2013) to having their registered office at to act as Licensed Agency for the purposes of the said Act for execution of fire prevention and life safety measures in relation to in class local authority- Subject to the provisions of sub-section (2) of section 28 of the said Act rule 20 of the Gujarat Fire Prevention and Safety Measures Rules, 2013, the licence will be valid for a period from to SEAL OF OFFICE Place Director Gujarat, Date : [PART-IV-B FORM A3 GUJARAT GOVERNMENT GAZETTE No., 19-08-2014 (See rule 13) Notice to Licensed Agency for suspension or cancellation of Licence WHEREAS a Licence to act as a Licensed Agency for the purposes of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Gujarat Act 11 of 2013), being a licence No. dated has been granted or renewed in the name of and the licence so granted or renewed was subject to the provisions of section 28 of the said Act and the conditions of licence, specified in rule 21 of the Gujarat Fire Prevention and Life-Safety Measures Rules, 2013; AND WHEREAS it is noticed that you are guilty of the following acts, namely:- (1) (2) (3) AND WHEREAS these acts amount to NOW THEREFORE, in exercise of the powers conferred on me by sub-section (1) of section 28 of the said Act (read with sub-section (4) of section 28 of the said Act), I, hereby call upon you to show cause in writing, within a period of 30 days from the receipt of this notice as to why the licence so granted or renewed in your favour should not be suspended or cancelled. SEAL OF THE OFFICE Place; Director PART-IV-BI GUJARAT GOVERNMENT GAZETTE No. EX. 19-08-2014

FORM m (See sub-rule (I) of rule 14) Certificate by the Licensed Agency for compliance of the Fire Prevention and Life Safety Measures- CERTIFICATE 246-23 Certified that I/We have executed the works towards compliance in relation to Fire Prevention_ and Life Safety Measures to be provided and performed other related activities required to be carried out; in the following building or premises, as required under the provisions of the Gujarat Fire prevention and Life safety Measures Act, 2013 (Guj- of 2013). Description and Location of Building or Premises Title details of the work and related activities which I or we have executed or performed are mentioned in the list appended herewith. Place : Date: Signature and Address of the Licensed Agency. Licence No Chief Fire Officer / Regional Fire Officer / Nominated Officer [*Note.- For each building a separate certificate is necessary]- 246-24 GUJARAT GOVERNMENT GAZETIE EX. 19-08-2014 FORM B2 (See sub-rule (2) of rule 14) [PART-IV-B Six monthly certificates to be given by the owner or the occupier for compliance of the Fire Prevention and Life Safety Measures CERTIFICATE Certified that i / We have carried out inspection of the Fire Prevention and Life Safety Measures installed in the following building or premises, namely* I fWe further certify that these installations in the above mentioned buildings are maintained, in good repair and efficient conditions during the- period , as under the provisions of the Gujarat Fire Prevention and Life Safety Measures •Act, 2013 (Guj. 11 of 20B). The details. of -the inspection of installations carried out by me/us are mentioned in the report appended herewith. Place: Date: Signature and Address of the Licensed Agency. Licence No: Chief Fire Officer / Regional Fire Officer / Nominated Officer [*Note:- detailed location and postal addresses are to be provided here]. PART-IV-B]- GUJARAT GOVERNMENT GAZETIE EX. 19-08-2014 FORM B3 (See sub-rule (I) of rule 15) 24605 Notice for removal of objects or goods likely to cause the risk of fire. To, Shri Whereas, Government has, by notification, Department, No. required that the owners or _published in the Gujarat Government Gazette, dated Occupiers of premises or any Class of premises used •in the following area, which in its opinion, are likely to cause risk of fire, to take such precautions as have been specified in the said notifications and as are reproduced here below- And whereas, you are the owner or occupier of the following premises, which fall in the area mentioned in the said Government notification- And whereas, on inspection of-the aforesaid premises, it is noticed that' the objects or goods mentioned in the list appended herewith are, such as are likely to cause risk of fire and are required to be removed to a place of safety. Now, therefore, in exercise of the powers conferred by sub-section (2) of section 22 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj. 11 of 2013) hereby give you notice that you shall forthwith remove the said objects or •goods-to a place of safety and submit the report in respect of your-. having done so to the undersigned within Place: Date: days*. Signature Name and Designation of the Officer competent to issue notice (*specify the period considering the urgency to remove the objects and goods.) 246-26 GUJARAT GOVERNMENT GAZETTE 19-08-2014 FORM B4 (See sub-rule (2) of rule 15) Whereas, by notice No - Notice to the owner or occupier to comply issued to you by . , dated . [PART-IV-B and received by you on you were required to remove forthwith or. goods specified in the list appended to the said notice, to a place of safety and to submit a report of you having done so to the undersigned; And whereas, it is found that you have not complied with the said notice and have not removed forthwith the said objects or goods to a place of safety and they are still lying where they were which is likely to cause the risk of fire. Now, therefore, in exercise of the powers conferred by sub-section (2) of section 22 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj- 11 of 2013)- I, hereby call upon you to submit your say, if any, addressed to the undersigned so as to reach by or before 5.00 p.m. on as to why the said objects or goods should not be seized-or 'detained or removed by taking assistance of a Police Officer- Place : • Date: Signature and Designation of the Officer- PART-IV-B] Shri or M/s GUJARAT GOVERNMENT GAZETIE EX. 9-08-2014 FORM B5 (See rule 16) Seizure or Detention or Removal Memorandum 246-27 Date and Time . Removal of objects or goods. Notice(s) No. Place of Seizure or Detention or Name and Addresses of Panchas. (1) (2) Name of the Police Officer, if any, present., The following property or objects or goods have been seized or. detained-or removed under-sub-section (2) of section 4 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj- 11 of 2013) for the reasons stated below:— Serial No Place from Particulars of Quantity where Seized (2) Signature of the person from whom seized- Signature of the Panchas (1) (2) Signature of the Police Officer, if any, present. Place: Date: Seized Property (3 (4 Reasons for Seizure or Detention Or Removal) (5) Name and Designation of the Officer competent to issue notice 246-28 GUJARAT GOVERNMENT GAZETTE FORM B6 (See rule 16) PANCHANAMA

19-08-2014 [PART-IV-B Notice(s) No Date and Time . Name of the building or premises and Address....-
 - Name and Address of the person, in charge and present on the Name and Address of the Panchas— (1)
 Shri/Smt Resident-of... (2) Shri/Smt . Resident of. --son/daughter/wife, of years- Occupation Age .
son]daughter/wife, of years- Occupation Age —We the above panchas are this... Designation Place .
 certain property or objects or goods from day called by Shri to witness the act of seizing or detainina or
 removing-which were possessed and exposed in the above mentioned building or premises. In
 our presence, the said officer namely, - correct. Serial No 1 . seized the following mentioned property
 which we. -testify to be Place from where Seized (2 Particulars of Seized Property or objects or goods 3
 Quantity 4 Reasons for Seizure or Detention . or Removal 5 The Panchanama is read over and explained to
 us and it is a correct account of what we saw- Signature Name and Designation of the Officer- Signature of
 the Panchas. (1) (2) Received the copy of the Panchanama. Signature of the person, in charge of the
 building or premises- PART-IV-BI To, 1, GUJARAT GOVERNMENT GAZETTE EX. 19-08-2014 FORM B7
 (See ND-rule (1) of Rule 17) Notice Of entry and inspection 246-29 empowered by sub-section (1) of
 section 24 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013(Guj. I of 2013) and sub-rule
 (1) of rule 25 of the Gujarat Fire Prevention and Life Safety Measures Rules, 2013> do hereby give you
 notice that on expiry of not less than three hours from the time of service of this notice upon you this time,
 I shall enter and inspect your premises bearing No, day at located at for the purpose of ascertaining
 adequacy and contravention of fire prevention and life safety measures as required to be provided by the
 provisions of the said Act. • Signature Name and Designation of the Officer. Date: 246-30 To
 GUJARAT GOVERNMENT GAZETTE EX , FORM B8 (See (2) of j 7) 19-08-2014 [PART-TV-B
 Notice to a Woman in the building or premises to withdraw therefrom empowered by sub section. (1) of
 section 24 of the -Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj. 11 of 2013) and sub-
 rule (2) of rule 25 of the Gujarat Fire Prevention and Life Safety Measures Rules, 2013, have- given a
 notice to the owner or occupier Of building or premises bearing No, located at less than three hours from
 the time of service of the notice, on him this that on expiry of not day at time, I shall enter and inspect the
 said building or premises for the purpose of ascertaining the adequacy and contravention' of fire
 prevention and life safety measures as required to be provided by or under the provisions of the said Act.
 Since you are in this building or premises, I hereby give you this notice that you are at liberty to withdraw
 therefrom before the aforesaid entry and inspection and you may withdraw now, if you desire to do so.
 Place: Date: Signature Name and designation of the officer. PART-IV-BJ GUJARAT GOVERNMENT
 GAZETTE EX. 19-08-2014 FORM B') (See rule 18) Inspection Report 246-31 After giving-a three hours'
 notice under sub-section (1) of section 5 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013
 (Guj- I of 2013)to the owner or occupier of entered and inspected the said building or premises on at I
 have for ascertaining the adequacy or contravention of fire prevention and life safety measures that are
 provided or are required to be provided in the said building or premises by or under the provisions of the
 said Act. 2- (a) (b) (c) The type* of occupancy in the said building or premises is as under,— (a) (b) (d) (e)
 (f) (g) (h) Residential Educational Institutional Assembly Business Mercantile Industrial Storage
 Hazardous Nature* of building or premises,— General Constructional Features Low fire risk-cement
 concrete or bricked-wall, or Medium fire risk-bricked-work and timber, or High fire risk-mostly timber
 framed such as timber floors, timber roof, timber-stair-case, etc- particulars of the building/premises,— (i)
 (ii) (iii) (iv) (v) (vi) (vii) Number of storeys and basement, if any Number of exits details of ceiling Number of
 stair-cases and whether enclosed or opened Verandah or balconies Attics, mezzanine floors, lofts, etc.
 Whether prescribed distance in respect of means of escapes is maintained or not. Details of other structures
 within 20 meters all around the building and spaces or approaches for fire vehicle. (ii) (iii) (iv) Structures
 North South East West Open spaces (d) Width of abutting road or street. 246-32 (e) (f) (1) (2) (3) Place;
 Date: GUJARAT GOVERNMENT GAZETTE EX., 19-08-2014 Maximum number of occupants,
 employees, visitors. [PART-IVAB Inadequacy or contraventions noticed in the building or premises
 during inspection are as under,— Signature Name and designation of the Inspecting officer- (*Maximum
 any other as may be relevant) PART-IV-BI GUJARAT GOVERNMENT EX- 19-08-2014 FORM BIO
 (See sub-rule (1) of rule 19) 246-33 Notice regarding inadequacies or contraventions regarding fire
 Prevention and life safety measures noticed during inspection Whereas, after giving you notice No. dated
 under sub-section (1) of section 5 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj- I
 of 2013), the nominated officer has or I have inspected the following building or premises, namely:—

and the following deviations from or contraventions the requirements with regard to the fire prevention and life safety measures or inadequacies or non-compliances* of such measures provided be provided therein with reference to the height of the building or the nature of activities carried on in such building or premises or part thereof have been reponed by the nominated officer or are notiged by me, (2) (3) Now,

Therefore, in exercise of the powers conferrr=d by section 6 of the 5aigl Act* I hereby direct you to undertake the following measures within days. after receipt Of this notice by yon,— (1) (2) (3) i hereby further direct you to report the compliance in this regard immediately to the undersigned. Si&iature Name and of the Place: officer. 246—34 GUJARAT GOVERNMENT GAZETTE EX., FORM Bik (See sub-rule (1) of rule 2 i) 19-08-2014 [PART-IV-B Notice for Appointment of Mie Safety Officer under section 12 of the Act Dated: WUEREAS the building/premises bearing No... . is comprised of and covered under First Schedule of rules. located at AND WHEREAS the owneffoccupier/an association pCsuch owners and occupiers were required to appoint a Fire Safety Officer under section 12 of the Act NOWTHF.REFORE, 1 Director [Nominated Authority appointed under the Act, call upon you to appoint a Fire Safety Officer within days failing which the owner or occupier or an association of such owners and occupiers shall be deemed to be in default jointly and severally and penal action shall be initiated under sub-section (I) of section 12 of the Act without any further notice oropportunity. The Regional Fire Officer Or the Officer — Place: Date: To the owner/occupier/an association of such owner.s and occupiers PART-IV-B] No. Shri - son of Shri . resident of . GUJARAT GOVERNMENT GAZETTE EX- 19-080014 FORM (See sub-jute (2) of rule 2 i) Certificate of Appoint lncn t of Fire Safety Officer Dated' 246-35 Passpoa size photograph of the member attested by Regional Fire Officer ör the Chief Fire omcer Certified that whose photograph appear on the right corner Of the certificate, has been appointed under section 12 of The Gujarat, Fite Prevention and Life Safety Measures Act, 2013 (Gujarat Act I of 2013) and vested with the powers, privileges and immunities ofa member of Fire Service with effect from In the event of any complain or for any other resons .recorded in writing, the Regional Fire Officer,or the Chief Fii•e Officer as the case be may terminate the appointment 'and take action under the rules and the Act, Date: Place: Signrature Name and Designation of the Member Attestation by-- 246-36 Certified that the basement(s) and GUJARAT GOVERNMENT GAZETTE EX-, 19-08-2014 FORM B13 (See sub-rule (I) of rule 23) Fire Safety Certificate No- Dated: (name of the building or (address) comprised of . (upper floors) owned/occupied by (name of the company / name of the owner/occupier) have complied with the fire prevention and fire safety requirements in accordance with section 18 and verified by the officers concerned of.Fire Service on (date of inspection) in the presence of -(name and addresses of the owner or his representative) and that the building/premises •is fit for occupancy with effect from for a period of . years in accordance with rules and sut\$ect to compliance of any specific laid by the issuing officer Issued on Plac.e. Signature (Name and designation of the authorized siYlatory) Computer -ID - Strike out whichever is not applicable, Eodorsement The No Objection Certificate issued by Fire Service stand cancelled . (reasons to be recorded). (Name and designation of the authorized signatory) and annulled due to PART-IV8] To GUJARAT GOVERNMENT GAZETTE EX I +0800 FORM BILI (See sutyrule (2) of rule 23) Application io Grant Fire Safety The Regional Fire Officer the ChiefFire Officer Sub: Application for grant of fire safety .certificate in respect of of building/premises). Sir This is to inform you that a fire safety certificate needs to be issued in of. 246-37 --(address of (name located the at -(address of the building) comprised of. -and having occupancies as . In this connection it is submitted that all the fire prevention and fire safety measures as recommended by you dated vide letter 'No. -'lave been provided in the building/premises and para wise compliance report is enclosed You are requested to kindly take action as necessary for grant of fire safety certificate for occupancy of the building/premises. Place: Date: Signature (Name of the Applicant) Contact details: Name in Full-- Tel. No. Mobile No: 246-38 GUJARAT GOVERNMENT GAZETTE EX., 19-08-2014 FORM B15 (See-sub-rule (2) of rule 26) Certificate for compliance of Fire Prevention and Life Safety Measures. [PAR'C-IV-B Certified that I have executed the works towards compliance in relation to Fire Prevention and Life Safety Measures to be provided and perforuned other related activities required to be carried out? in the following building or premises, as required under the provision' of the Gujarat Fire Prevention and Life Safety Measurb Act, 2013 (Guj. I of 20 i 3). Description and Location of Building or Premises Tile details of the work and related activities which I or we have executai or performed are mentioned in the list appended baewith. Place : Date : Sigtur and Address of the Fire Safety Officer. Licence No Signature of the occupier and the owner [

*Note.- For each building a separate certificate is necessary], PART-IV-BJ GUJARAT GOVERNMENT GAZETTE EX- 19-089014 FORM c 1 (See rule 28) Form of Declaration By Erector (Of A Pandal Declaration By_ Erector Of Pandal Under Section 27 Of The Act 246-39 registered office at do hereby declare that the pandal erected at .(name of the erector of pandal) -having measuring-- meters by meters shall remain in place with effect from to arid that fire prevention and fire safety measures .assequiredunder-rule 40 of the Gujarat Fire Prevantaion and Lief Safety Rules 2013 have been provided therein and further that the Complete erection of panda! and electrical services are in conformity with the standards. Also, it is declared that no storage/use of the flammable liquid or gases is done in the panda! and that electrical wiring has been done in conformity with Indian Electricity Rules by authorized persons- I, also, declare that following trained fire fighting staff shall remain on duty during the occupancy of the pandal:- 2 (Signature of erector of pandal) Dated:, Place: 246-40 GUJARAT GOVERNMENT GAZETTE EX., 19-08-2014 FORM (See sub-rule (2) rule 29 & sub-rule (8) rule 31) Seizure Order Date & Time Case No. WIIEREAS a report has been received from the authorised fire officer dated tPART-IV-B regarding certain goods/objects that are imminent cause of risk of fire/ obstruction to fire fighting in the premises or building or temprory structure, shamiyana or tent or mandap or-pandal eracted or or occupied by you.

WHEREAS you have failed to carry out the orders of the authorised officer under sub-section (I) of section 27 of the Gujarat Fire Prevantaion and Lief Safety Measures Act, 2013 (Guj. Act I of 2013). AND WHEREAS you have faild to make representation under sub-section (2) of section 27 of the Gujarat Fire Prevantaion and Lief Safety Act, 2013 (Guj- Act I I of 2013). or the reasons submitted by you vide letter. dated are not found satisfactory. NOW THEREFORE I, (name of the Authority) (designation) empowered under sub-section (3) of section 27 of the Gujarat Fire Prevantaion and LiefSafety Act, 20 B (Guj. Act of 2013)- hereby order to seize, detain or remove the encroachment of the following goods/objects for the reasons stated against each. Place from where to be Particulars of objects or goods to Quantity Reasons for seizure and seized (Signature of Authority) Name and Designation To 1. pandal). 2. 3. seized (Name and address of the Owner/occupier of the building or premises or PART-IV-BI GUJARAT GOVERNMENT GAZEFITE EX. i 9-08-2014 FORM C3 (See sub-rule (2) rule 29) Panchnama 246-41 I 2- 3. Name and address of Owner/occupiei Name and address of the person present Name and Address of the Panchas.- a) b) c) d) c) a) g) h) ShrVSmt •Sfo-D/oYW/0. Resident of Age (Years) Occupation Shri/Smt S/o.D/0./W/o. Resident of Age (Years) Occupation We, the above Panchas are this. day designation to Place from Case No- Place Date Time called by ShrVSmt. witness the act of seizing of certain objects or -goods address of the building/premises/pandal which were possessed and exposed in the premises/building/pandal of the owner/occupier. In our presence, the said (name and designation of the officer) seized the following mentioned objects/goods which we testiö' to be correct. Particulars of seized objects or Quantity Place from where seized Reasons for seizure and detention The Panchnama is read over and explained to u; and it is ujrrcet account of when we saw. Signature of Panchas: (Signature'oftbe Authority seizing the goods) 0) (2) Received the copy of Panchnama. of the owner/occupier GOVERNMENT GAZETTE EX., 19-08-2014 FORM C4 (See sub-rule (3) of rule 29 & sub-rule (9) of rule 31) Notice for Claiming of Seized Goods [PART-IV-B WHEREAS certain objects/goods ".yere seized on (date) from premises located-sat (address of the premises) in case No- dated the Act vide panchnama No. dated WHEREAS the said objects/goods are now lying at the premises). NOW THEREFORE I (name) under section 27 of (address of (Designation) having office day between do hereby call upon you to remove the said on any working Hrs to Hrs within days at your risk and cost failing which it shall be presumed that you don't intend to claim the' said objects/goods and the Same shall be disposed off by way ot- public auction under the provision of sub-section (S) of section 27 of the Gujarat Fire Prevantaion and Life Safety Act, 2013 (Guj- Act I I of 2013)- without any further notice- (Signature) Name Designation Dated: Place: PART-IV-BI GUJARAT GOVERNMENT GAZ.EITE EX- 19-08-2014 FORM C5 (See rule 30) NOTICE Date: WHEREAS the services ot* the Gujarat State Fire Service were requisitioned on at to assist in the fire fighting and/or rescue operation during the out break of fire at (address of the premises). -o.....llours WHEREAS at.. (no of appliances) along with members of fire sewice responded from (name of fire stations) on - hours and returned back to their respective fire stations on Hours. WHEREAS a sum of Rs- towards the deployment of the Fire Servicz is due to be paid by you. at (Designation) call NOW THEREFORE, r upon you to pay the said anlount within State Fire ServZe payable-at Gandhinagar- (name) days through bank draft payable to Director, Gujarat Signature -Director, Gujarat State Fire

Service 246-44 No. GUJARAT GOVERNMENT GAZETTE EX., FORM C6 (See sub-rule (2) of rule 31) NO. 19-08-2014 (PART-IV-B OF SUB-DIVISIONAL MAGISTRATE Date: WHEREAS a report has been received from the Director, Gujarat State Fire Service under sub-section (6) of section 27 of the Act regarding removal of encroachment or objects or goods causing a risk of fire or obstruction to fire fighting at NOW THEREFORE (Designation) call upon you to show cause within (address of the premises)- (name) (days) from receipt of this notice under subsection (6) of section 27 as to why action should not be initiated as necessary under the provisions of the Act. Signature Sub-Divisional Magistrate To, PART-IV-BJ GUJARAT GOVERNMENT GAZETTE EX., 2014 FORM Cv (See sub-rule (3) or rule 31) _ 46-4 S No. Declaration by the promoter, the (Manager or the owner or the occupier of premises) Date: WHEREAS, the undersigned promoter or the organizer or the owner or the occupier of premises are intending to use the premises bearing R.S.No./C.S.No. property No- namely: having the postal address . In the said premises we intend to use it for the following purpose (describe the purpose) Therefore, as required under sub-section (2) of section 27 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj. 11 of 2013) we declare to have made measures as prescribed in the under sub-section (4) of section 27. The aforesaid premises shall be open for inspection to the authorised officer to access the correctness and adequacy of the measures. We therefore request to grant necessary permission for the use of the premises. Signature Promoter or the organizer or the owner or the occupier of premises 246-46 No. GUJARAT GOVERNMENT GAZETTE EX., 19-08-2014 FORM C8 (See sub-rule (3) of rule 31) Permission to grant use of temporary structure Date: WHEREAS the building/premises bearing No. at [PART-IV-B -located to be used for the following purpose Wherein, the promoter or the organizer or the Owner or the (Occupier of premises have submitted the dated under sub-rule (3) Of rule 31 in form 'C'. The inspection for the aforesaid premises is carried out on dated officer. The permission is granted to use. The premises for the aforesaid purpose from date by authorised to date To, with the following conditions. Signature of Authorised Officer PART-IV-BI Appeal No Appellant: GUJARAT GOVERNMENT GAZETTE EX. 19-08-2014 FORM C9 (See sub-rule (10) of rule 31 & sub-rule (1) of rule 36) FORM OF APPEAL TO THE APPELLATE AUTHORITY of 20. Son of Shri.. Versus 246-47 resident of Municipal Commissioner/Nominated Authority/Director/ Sub Divisional Magistrate-Respondent Appeal under section 03 of Gujarat against the notice (order of Shri Nominated Authority/ Sub Divisional Magistrate /Director dated: Sir, The Appellant respectfully sheweth as under: 1. 2- 3- 4. 5- 6. Statement of facts. Ground of Appeal. Fee of Rs. 5000/2 has been paid vide receipt No.. Appeal is within time- -dated No other Appeal or any matter relating to the subject matter of this appeal is pending in any court of law. Relief claimed. Signature of Authorized representative, if any. Signature of Appellant VERIFICATION the appellant do hereby declare that what is stated above is true to the best of my personal knowledge and belief suppressed any material facts: Verified at Place: day of.. Signature of Authorized representative, if any. Signature of Appellant GUJARAT GOVERNMENT GAZETTE EX., 19-08-2014 24648 FORM m (See sub-rule (2) of rule 41) Form of Fire Report Current date: 1. Fire Report Number

2. Operational jurisdiction of Fire Station. 3. Information received from- 4. Name of the caller

5. Phone number of the caller. 6. of the incident place- of receipt of call. Time of receipt of call

9. Time of departure from Fire Station. Approximate distance from Fire Station- 11. Time of arrival at Fire Scene

12. Nature of call. 13- Date of leaving from fire scene. 14. Time of leaving from fire-scene. of occupancy

16. Occupancy details in case of others

17. Category of fire- Type of building- 19. Building details in case of others. 20. 21- Details of affected area. 22- Details of injury

23. Details of death(s)- (PART-IV-B Divisional Fire Officer This is a computer generated report. Neither department nor its associates, information providers or content providers warrant or guarantee the timeliness, sequence, 246-49 To, The Officer In-charge, GUJARAT GOVERNMENT GAZETTE Ex- 19-08-2014 FORNI 02 (See sub-rule (1) Of rule 43) order to disconnect electricity / water supply Sub- No. • Located at Sir, i am to state that by an order No. dated of the Gujarat Fire Prevention and Life safety Measures Act, 2013 (Guj. of 2007) 1, the undersigned had required and directed the persons in possession or in occupation of the above said place or building or part thereof to remove themselves forthwith from or building or part thereof as due to inadequacy of fire prevention and life safety measures, the condition of such place or building of part thereof is dangerous to the persons or property therein- these persons have however not removed themselves from such *place or building or part thereof in compliance Of the order so made and they still continue to be in possession or in occupation thereof. In the event of non-compliance of the order so made under sub-section (1) of the said section 26, the undersigned is empowered under subsection (2) of the said section 26 to direct the authority responsible for supply of electricity or for supply of water, as the case may be, to disconnect the supply of electricity or water to such *place or building or part thereof and such authority shall comply with such direction. As the persons in possession or in occupation of the abovementioned *place or building or part thereof have not removed themselves as directed by the said order, there is a non-compliance thereof and I, therefore, direct the authorities executed to disconnect forthwith the supply of electricity or water of the said *place or building or part thereof. Compliance in this behalf may please be reported to me immediately. Place: Date: (*Mention any of these as may be relevant) Signature Name and designation of the officer. {PART-IV-B (See sub-rule (k) of 43) Order to remove persons from dangerous place officer in-charge. To, The Officer In-charge, Located at thereof bearing No. Sub- issued under sub-section (1) of section 26 of the- Sir, dated Gujarat Fire Prevention and life safety Measures 2013 (Guj. 1 of 2013) I the undersigned, had required and directed the persons in possession or in occupation of the above said place or building or part thereof to remove themselves forthwith from such *place or building or part thereof as due to inadequacy of fire prevention and life safety measures, the condition of such place or building or part thereof is dangerous to the persons or property therein. These persons have however not removed themselves from such *place or building or part thereof in compliance of the order so made and they still continue to be in possession or in occupation thereof. [In the event of non-compliance of the order so made under sub-section (1) -of the said section 26, the undersigned is empowered under sub section (2) of the said section 26 to direct (2 any police officer, having jurisdiction in the area, to remove such' persons from such *place or building or part thereof and such police officer shall comply with such direction. The abovementioned *place, building or part thereof is situated within your area of jurisdiction- As the persons in possession or in occupation of the abovementioned *place or building or part thereof have not removed themselves as directed by the said order, there is a non-compliance thereof and I, therefore, direct you to remove such persons from such *place or building or part thereof and seal the *place or building or part thereof as required under sub-section (3) of section 26 of the Act. Compliance in this behalf may please be reported to me immediately. Place: Date: (*Mention any of these as may be relevant) Signature Name and designation of the officer. PART-IV,,BI No- No. GUJARAT GOVERNMENT GAZETTE EX- 19-08-201

FORM D4 (See rule 45) Order to Deliver Possession Fighting Equipment or Property Date: 246-51 For the purposes of fire fighting operations, or as the case may be, during the ongoing fire fighting operations at the following building or premises, namely: I, the undersigned in exercise of the power under sub-section (I) of section 13 of the Gujarat Fire Prevention and Life Safety Measures Act, 2013 (Guj- 11 of 2013), read with rule 59 of the Gujarat Fire Prevention and Life Safety Measures Rules, 2013 hereby require you to deliver the possession of the following fire equipment or property to the undersigned forthwith on receipt of this order and the said equipment or property shall be released from requisition and be restored to you as soon as may be, after fire fighting operations are over, 1. Place; Director/ Chief Fire Officer/Fire Officer To, 246-52 GUJARAT GOVERNMENT GAZETTE EX-, 19-08-2014 FORM D5 (See rule 46) [PART-IV-B Report of Damage caused to Premises or Property by Fire Officer during Fire Fighting and Rescue- Operations. Name of the Fire Station: (1) (2) (3) (4) (6) (7) (8) (9) (10) Date and time of call received— Fire report No. and date— Name and Address of the premises where fire occurred— Description of property involved— Name and Address of the premises to Which damage caused— Nature and extent of property to which damage caused— Description and details of damage caused to the premises or property in the course of fire fighting and rescue operations— Reasons for breaking or pulling down the structures, if any— Loss of the amount, if any made by the party— Name and Designation of the officer of the authority designated under sub-rule (2) of rule 24— Remarks- Submitted through Signature Name-and Designation of the Officer In-charge of operations, By order and in the name of the Governor of Gujarat, NEELA MUNSHI, Officer on Special Duty & Ex-Officio Deputy Secretary to the Government of Gujarat. Urban Development & Urban Housing Department GOVERNMENT CENTRAL PRESS, GANDHINAGAR.

